


Building Safety Certificate


The school building of Rosemary Public School Haripur Tahsil Haripur district Kangra (HP) was inspected by me with the concerned junior engineer. No earthquake resistant norms have been adopted for the building. No structural drawing approved by the competent government agency have been produced. The structure is a non engineering structure. Face the structural safety of this building cannot be insured specially from earthquake point of view. This building has been constructed in the year 2013. This but will not be responsible for any type of loss of life and property etc., If this structure fails under any circumstances. However as per visual inspection the buildings appear to be safe at present under static loads. This certificate is valid for 5 years.

Note:- the school administration shall be responsible for security of the school children in the school complex.

Date. 25/12/2021

Place... Haripur


Junior Engineer
Section Haripur
HPPWD Sub-Division
Haripur


Assistant Engineer
HPPWD Sub-Division
Haripur


Executive Engineer
Dehra Division HPPWD
Dehra