

# Certificate

To whom it may concern

This is to certify that Rosemary Public School has been using tap water supplied by IPH Department for drinking purpose since the opening of the school. It has been found that sanitary conditions of drinking water and place around drinking water resources are good and hygienic.

Date 07/03/2023

1  
23  
Medical Officer  
Medical Officer  
Dist. Kangra (H.P.)  
CHC  
Haripur

**HIMACHAL PRADESH  
JAL SHAKTI VIBHAG  
WATER TESTING LABORATORY JSV DEHRA**

Email:- dehralab@gmail.com	Mob.No. 8219970969	Sr. No. 4183
----------------------------	--------------------	--------------

**Detail of the Sample:- Principal Rosemary Public School Haripur**

Name of Scheme:- Private Sample  
 Date & time of collection - 14/01/2023      Date & time of report at - 14/01/2023  
 Date & time Commencing of test - 14/01/2023

**A. PHYSICAL PARAMETERS (Limits: Based upon BIS :10500-2012)**

S.N	TEST PARAMETER	UNITS	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT (in the absent of alternative source)	TEST RESULT
1	Colour	Hazen Units	5	15	0
2	Odour		Agreeable	Agreeable	Agreeable
3	Taste		Agreeable	Agreeable	Agreeable
4	Turbidity (NTU)	NTU	1	5	1.20
5	PH		6.5-8.5	No relaxation	8.11

**B. CHEMICAL PARAMETERS (Limits: Based upon BIS : 10500-2012)**

6	TDS/Elec. Conductivity	Mg/l	500	2000	155
07	Total Alkalinity	Mg/l	200	600	164
8	Chlorides (as Cl)	Mg/l	250	1000	15
9	Total Hardness	Mg/l	200	600	160
10	Magnesium	Mg/l	30	100	12
11	Calcium	Mg/l	75	200	44
12	Free Residual Chlorine	Mg/l	0.2	1	0
13	Total Coliforms	Number/100	Nil	Nil	Nil

*Note:- Indicate discrete sampling. Water quality monitoring to be continued only if these are traced in drinking water sources.*

1. Sample will be stored for a period of 3 days from the date of issue of report.
2. Results refer only to tested samples and parameters tested.
3. This report should not be produced partially or fully without approval of the signatory for legal purposes.
4. 12 and 13 test parameters are not recognised by the NABL body.

*VH*  
Asst. Chemist



*[Signature]*  
Assistant Engineer  
JSV Sub-Division Dehra